SINGLE HEADED STANDPIPE

PRODUCT CODE	STP02
Approvals	BS336:2010 BSI Kitemark LPCB
Height	925mm
Width	255mm
Inlet	3” BSRT
Outlet	2.5” BS336
Body material	Aluminium
Working pressure	16 Bar
Seat test pressure	24 Bar
Weight	3.6kg



KM 726502

LPCB Cert ref. 1153g

Express Fire Equipment Ltd., Units 3, 4, 6 and 10 Mersey Road Industrial Estate,
Mersey Road North, Failsworth, Manchester, M35 9LU.
Tel: 0161 688 5050 | Web: www.expressfire.com | Email: info@expressfire.com

Express Fire Equipment Ltd



Technical specification
1.the product according to BS 336:2010
Production and testing
2.WP:16BAR TP:24BAR
3.Silver spray paint surface
4.Strength test for standpipes:Assemble the standpipe on a fixed mounting provided with a screwed outlet conforming toBS750:2006,Clause.Apply a pulling force of 1.1KN at an outlet at right angles to the axis of the shaft for a period of 60±10S.
Examine for damage or deformation

NO.	CODE NAME	NAME OF PART	QTY	MATERIAL
16	EF-STP02-1	LOWER PART OF LUG	1	CZ122
15	EF-STP02-2	Pin	2	SS304
14	EF-STP02-3	Sping	1	SS304
13	EF-STP02-4	Release bolt	1	CZ122
12	EF-STP02-5	Locknut	1	BS-1C22
11	EF-STP02-6	Cap	1	CZ121
10	EF-STP02-7	UPPER PART OF LUG	1	CZ122
9	EF-STP02-8	Washer	1	Natural rubber
8	EF-STP02-9	Outlet	1	LM25-T6
7	EF-STP02-10	Clip	1	304
6	EF-STP02-11	Connector	1	LM25-T6
5	EF-STP02-12	"O"-Ring	2	NBR
4	EF-STP02-13	Connector	1	LM25-T6
3	EF-STP02-14	Standpipe shaft	1	6082
2	EF-STP02-15	Washer	1	Natural rubber
1	EF-STP02-16	Standpipe base	1	LM25-T6

Express Fire Equipment Ltd., Units 3, 4, 6 and 10 Mersey Road Industrial Estate, Mersey Road North, Failsworth, Manchester, M35 9LU.
Tel: 0161 688 5050 | Web: www.expressfire.com | Email: info@expressfire.com